

FIRE SAFETY CERTIFICATE

No. 250, No. 3/ FS/Online/2023

Dated: 30-03-2023

Certified that the Riverdale International School at Village Khamaria, P/O/ Bazpur, Distt- U.S. Nagar, Uttarakhand, comprised of Zero basement(s) and 03 (01 ground & 02 upper floors) owned/ occupied by Riverdale International School have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service 23/03/2023 in the presence of Mr. H.S. Sidhu, Chairman, Ranjit Nagar Farm, Bazpur and that the building/premises is fit for occupancy upto classes XII with effect from 30-03-2023 for a period of 03 years in accordance with rule and subject to compliance of specific conditions as appended -

1. All exits or aft sets and stairways shall be kept clear in every case.
2. It is necessary for all the employees of your organization to have knowledge of available fire fighting equipments and safe construction procedure (Evacuation).
3. It shall be the responsibility of the management to keep all the fire fighting equipments in working condition. The installation of excessive firefighting equipment should not be taken to mean that there should be no incident of fire could. Therefore, the management should always take fire prevention measures.
4. Verification of installation of electrical equipment, painting, structure, stability set bank area and construction land use change etc. should be done by the concerned officer.
5. Before expansion / additional construction of the institute, it will be necessary to make additional fire fighting arrangement according to the standard after getting the map approved from this office.
6. Trimming of any inflammable material around the electrical switch board / electrical panel will not be done. On storage it will be considered as negligence of the management and will not be recommended for insurance claim in case of fire accident in future.
7. On operation of computer and other labs in the institute, one CO2 extinguisher capacity 8.5 kg in computer lab, one ABC fire extinguisher capacity 10 kg in otherlab, 04 nos sand bucket and one no ABC fire extinguisher capacity 10 kg near generator. It will be mandatory to set up a number of sand buckets.

Issued on 30-03-2023 (date of issue) at Udhm Singh Nagar by

Signature with Seal:

Name

Designation

Name & Address of Department/ Office

अग्निशमन अधिकारी
काशीपुर (उधम सिंह नगर)

To

.....
(Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled and annulled due to

.....
(reasons to be recorded). (Name and designation of the authorized signatory)

H.S. Sidhu

CHAIRMAN

Riverdale International School
Bazpur (U. S. Nagar)

[Signature]

Principal

Riverdale International School
Bazpur